

*Trent Cook*  
*High School Principal*  
*903-584-3443*

*Kimberlyn Snider*  
*Elementary Principal*  
*903-584-3401*

*Neches Independent School District*

*P.O. Box 310 – Neches, Texas 75779-0310*

*Randy Snider, Superintendent*

*Phone 903-584-3311 – Fax 903-584-3686*

Date: 1/6/2017

To: Staff, Parents, Teachers, Board members and Patrons of  
Neches Independent School District

Subject: **ANNUAL REPORT AND MANAGEMENT PLAN REVISIONS (2016)**

**This notice is furnished as required by Code 40 of Federal Regulations 763, Subpart E, Section 763.93 (g).**

There were no significant changes in the condition of the identified asbestos-containing materials from the initial inspection. Asbestos on the **High School Campus** is located in four known areas. Classrooms 242, 244, 245 and 246 (Building 1) have inaccessible asbestos tiles that are enclosed **under the built-in shelves**. They are not scheduled to be removed. We have two TSI wrapped water pipes: one located in the **science room storage closet** and one in the **hot water heater room** for the kitchen. The pipes are in good condition with no observed damage and are not accessible to the public. The ceiling in the **maintenance storage room** (Building 6) has tape and bedding joint compound that contains only 1 - 3% asbestos. It is in good condition. The room is kept locked at all times unless access is needed by maintenance personnel. **No known asbestos-containing materials are on the Elementary Campus.**

The management plan has been updated in accordance with the Asbestos Hazard Emergency Response Act. Copies of the inspection report and management plan update are available for inspection at the Superintendent's office during business hours.

Shain Emerine  
Asbestos Designated Person

# ASBESTOS ANNUAL REPORT